



FIRE SPRINKLER MONITORING SYSTEM

These guidelines are to be followed when a fire alarm system within the City of Rockwall is to be installed or modified. These guidelines are not to be interpreted as containing all data required for proper design, installation, or approval.

All fire sprinkler monitoring systems shall conform to the 2015 International Fire Code and current edition of NFPA 72 as adopted and amended by the City of Rockwall. These guidelines are not intended to replace, nor supersede any codes and/or ordinances adopted by the City of Rockwall, or determinations and positions of the Rockwall Fire Marshal Division.

Fire Sprinkler Monitoring Panel / Notification Power Supplies

- 1) Only one fire sprinkler monitoring panel is allowed per building.
- 2) New fire sprinkler monitoring systems shall be addressable.
- 3) Fire sprinkler monitoring panel or an annunciator panel is required in the fire riser room and at the main entry unless otherwise approved.
- 4) Fire sprinkler monitoring panel shall be labeled "FIRE SPRINKLER MONITORING PANEL"
- 5) Systems shall be resettable without any special knowledge or the use of an access code.
- 6) Primary power shall be a dedicated circuit that is labeled both in the fire alarm panel / notification power supply (panel A circuit 2) and the circuit breaker in the electrical panel is indicated in red and labeled "Fire Sprinkler Monitoring Circuit" and locked or otherwise secured from unauthorized access.

Wiring

- 7) All initiating device circuits and signal line circuits shall be Class "A" with a minimum of 4-feet separation horizontal and one foot vertical between supply and return circuit conductors
- 8) All notification appliance circuits shall be Class "B"
- 9) The Initiating Device Circuit from an addressable device used to monitor the status of a suppression system may be wired Class B, provided the distance from the addressable device is within 10-feet of the suppression system device.
- 10) Wiring may not be supported by the ceiling grid support wires.
- 11) Suspended wires added to support the fire sprinkler monitoring wiring must be painted red and attached to the above structure and to the ceiling grid.

Devices

- 12) Waterflow switches must activate an alarm within 45-90 seconds and shall be non-silencable.
- 13) Sprinkler and standpipe system water-flow detectors shall be provided for each floor tap to the sprinkler system.
- 14) Manual dry standpipe systems shall be supervised with a minimum of 10 psig and a maximum of 40-psig air pressure with a high/low air supervisory alarm.
- 15) A smoke detector is required over all fire alarm control panels, notification power supplies, and monitoring transmitting equipment.
- 16) A pull station is required to be located near the fire sprinkler riser and shall be a double action type.
- 17) Duct detectors shall not be tied into the fire sprinkler monitoring system.
- 18) Kitchen hood systems shall be tied into the sprinkler monitoring system.
- 19) Tamper switches shall be individually addressed and labeled to match the description that is programmed in the fire alarm control panel. (Example: Tamper 1)



FIRE SPRINKLER MONITORING SYSTEM

- 20) All valves controlling the water supply for automatic sprinkler systems, pumps, tanks, water levels and temperatures, critical air pressures, and water-flow switches except for fire department hose connection valves on all sprinkler systems shall be electronically supervised.
- 21) Provide a weatherproof horn strobe minimum 75-candela strobe rating, installed as close as practicable to the fire department connection.

Documentation

- 22) An installation certificate shall be provided
- 23) Operating, testing and maintenance instructions and record drawings (“as-builts”) and equipment specifications shall be provided at an approved location.

Fire Pumps

- 24) Fire pumps shall be monitored in accordance with NFPA 20 and NFPA 72.

Fire Sprinkler Monitoring System Monitoring

- 25) Monitoring of the fire sprinkler monitoring system shall be Contact Identification.

Inspection Requirements

- 26) Rough Wiring/ above ceiling: All fire sprinkler monitoring wiring will be inspected for proper installation and penetration of any firewalls. Fire sprinkler monitoring wiring shall not be tied to ceiling grid wire.
- 27) Audible / Visual Device Test: test all audible/ visual devices.
- 28) Initiating Device Test: Test all fire alarm initiating devices for Alarm conditions.
- 29) Waterflow: The waterflow alarm will be tested by opening the inspectors test connection. The time delay feature on the flow switch switches must be 45-90 seconds.
- 30) Central Station Monitoring: Verify Contact I D. Standard response to contact Fire Department shall be within 3 minutes.
- 31) Device Address Test: Verify address and description of all devices.
- 32) Final: Final inspection.

Fire sprinkler monitoring system modification requirements- Plan submittal is only required for the following modifications:

1. Addition or modification to initiation devices (such as smoke, heat, pulls and water flow switches)
2. Panel Replacement (requires acceptance test)
3. Addition of Power Supply or Panel of any type

Minor fire sprinkler monitoring system modifications (such as adding horn/strobe for fire sprinkler monitoring or expanded notification coverage) do not require plan submittal. Work not requiring plans submittal: Contractors shall install a white service tag indicating location (i.e. Suite #) and scope of work (i.e. “Added horn/strobe”).

Submittal Requirements

See our website for all submittal requirements.