



**STATE HIGHWAY 276**

**MATCHLINE SHEET 24**

**MATCHLINE SHEET 25**  
**MATCHLINE SHEET 26**

**MATCH**

**LEGEND**

- EXISTING SS LINE
- EXISTING WATER LINE
- PROPOSED SS LINE
- PROPOSED WATER LINE
- PROPOSED FIRE HYDRANT
- PROPOSED TEE
- PROPOSED VALVE
- PROPOSED FIRE DEPARTMENT CONNECTION
- PROPOSED WATER METER

**NOTE:** SEE SHEET 26 UTILITY PLAN FOR WATER METER AND SANITARY SEWER SERVICE SCHEDULE



- NOTES:**
1. FIRE LINE SHALL HAVE MIN. 10' SEPARATION FROM ANY UTILITY (DOMESTIC WATER SERVICE, SANITARY SEWER SERVICE, ETC).
  2. FIRE HYDRANT NEXT TO PARKING AND/OR STRUCTURE MUST HAVE 5' CLEARANCE.
  3. ALL FIRE HYDRANTS SHOWN ON THESE PLANS ARE WITHIN MIN. 10x15' EASEMENTS.
  4. REFER TO SHEET 26 FOR WATER METER TABLE.
  5. REFER TO SHEET 26 FOR 2" TAP TO 1.5" SERVICE DETAIL.
  6. SANITARY SEWER LINES 10" AND 12" ARE PUBLIC LINES. ALL OTHER PROPOSED SANITARY SEWER LINES ON THIS PROJECT ARE CONSIDERED PRIVATE.
  7. ALL SANITARY SEWER MANHOLES TO BE SEALED.
  8. CONTRACTOR TO ADJUST PROPOSED MANHOLE RIM ELEVATION TO MATCH PROPOSED FINISH GRADE.



**RECORD DRAWING**  
RECORD INFORMATION PROVIDED BY  
CONASTER CONSTRUCTION, FORT WORTH, TEXAS  
ELEVATION VERIFICATION PERFORMED BY  
SURVEY CONSULTANTS, INC., PLANO, TEXAS

REV.	DATE	REMARKS	BY

**UTILITY PLAN**  
**MANSIONS FAMILY**  
**CITY OF ROCKWALL, TEXAS**

**RKM Consulting Engineers, Inc.**  
7616 LBJ Freeway, Suite 530  
Dallas, Texas 75247  
phone (214) 432-8070  
fax (214) 432-8089  
www.rkm.com

CHECKED	DESIGN	DRAWN	JOB	DATE	SCALE	SHEET
RKM	JRY	JRY	1026-005	05/27/09	1"=40'	<b>25</b>

