



EXISTING UTILITY POLE AND OVERHEAD UTILITIES TO BE RELOCATED BY UTILITY COMPANIES. CONTRACTOR TO COORDINATE WITH UTILITY COMPANIES AND ALL AFFECTED BUSINESS OWNERS PRIOR TO SERVICE INTERRUPTIONS.

(2) EXISTING UTILITY POLES AND OVERHEAD UTILITIES TO BE RELOCATED BY UTILITY COMPANIES. CONTRACTOR TO COORDINATE WITH UTILITY COMPANIES AND ALL AFFECTED BUSINESS OWNERS PRIOR TO SERVICE INTERRUPTIONS.

EXISTING UTILITY POLE AND OVERHEAD UTILITIES TO BE RELOCATED BY UTILITY COMPANIES. CONTRACTOR TO COORDINATE WITH UTILITY COMPANIES AND ALL AFFECTED BUSINESS OWNERS PRIOR TO SERVICE INTERRUPTIONS.

UTILITIES RELOCATION PLAN NOTES BY SYMBOL 'O'

- ① EXISTING SERVICE ENCLOSURE TO REMAIN.
- ② INSTALL NEW 4" PVC CONDUIT WITH MULE TAPE FROM EXISTING SERVICE ENCLOSURE TO NEW UTILITY POLE. RISE UP POLE 10'-0" PER ONCOR SPECIFICATIONS.
- ③ INSTALL NEW PRIVATE METER POLE TO MATCH EXISTING WOOD POLES.
- ④ RELOCATE TENANT METER AND WEATHERHEAD FROM EXISTING POLE INDICATED, TO NEW PRIVATE METER POLE AND RECONNECT TRIPLEX SERVICE CONDUCTORS.
- ⑤ EXISTING TRIPLEX SERVICE DROP, RECONNECT TO RELOCATED METER AND WEATHERHEAD ON TENANT METER POLE INDICATED.
- ⑥ EXISTING TRIPLEX SERVICE DROP TO BE RECONNECTED TO NEW UTILITY COMPANY SERVICE POLE BY ONCOR.
- ⑦ EXISTING 2" RGS CONDUIT SERVICE MAST AND WEATHERHEAD TO 4'-0" ABOVE ROOF LINE IF DIRECTED BY ONCOR.
- ⑧ EXISTING METER, SERVICE MAST AND WEATHERHEAD TO REMAIN.
- ⑨ RELOCATE EXISTING METER AND SERVICE RISER TO SIDE OF BUILDING INDICATED. EXTEND SERVICE RISER PER ONCOR REQUIREMENTS.
- ⑩ INSTALL NEW FEEDER FROM RELOCATED METER TO EXISTING TENANT PANEL. 3/4" CU - 2" RGS CONDUIT.
- ⑪ EXISTING TENANT PANEL TO REMAIN.
- ⑫ TELEPHONE TERMINAL SERVICE BOX TO BE RECONNECTED TO NEW TELEPHONE SERVICE DROP BY TELEPHONE COMPANY. COORDINATE WORK WITH TELEPHONE COMPANY.
- ⑬ NEW TRIPLEX SERVICE DROP BY ONCOR. COORDINATE WORK WITH ONCOR.

UTILITY CONTACTS	
Oncor Electric Delivery Mr. Phil Dickerson (912) 551-6712	AT&T Telephone Mr. Brian Duncan (903) 451-2303

submittals / revisions

no.	date	detail
▲ 4/2/2014		Electrical Revisions

12024
 Its project number
 02.26.2014
 date
 C.A.D.
 drawn by
 J.W.
 checked by



ENTIRE NEW DRAWING

EA ENGINEERING ASSOCIATES
 TX REG #F-4925
 Ph: 940.427.8487 Fax: 940.427.8499
 P.O. Box 167 Alford, TX 76225

sheet title
Utility Relocation Plan - Electrical
 sheet number
EL2.04