

THE HARBOR ROCKWALL, TEXAS

REGISTRATION

NO.	ISSUE/REVISIONS	DATE
1	POST-BID ADDENDUM	01/17/08
2	AS BUILT	11/10/08

SHEET TITLE

**PLAZA
 DISCHARGE PIPE
 PLAN**

JOB NO. 4930
 DATE: 01/12/08
 DRAWN BY: J. HARRIS
 FILE: 4930_THEHARBOR_ASBUILT-110706
 SHEET NUMBER

LW.08

SYM	SIZE	DESCRIPTION	#REQ'D
5	1"	SCH. 80 PVC WATERSWITCH SUPPLY AT FIXTURE	48
6	4"	SCH. 80 PVC SUPPLY MANIFOLD PIPING TO WATERSWITCH SUPPLY	2
7	6"	SCH. 80 PVC MAIN SUPPLY TO 4" MANIFOLDS	2
8	3"	SCH. 80 PVC MAIN RETURN TO CENTER NOZZLE ASSEMBLY	1
9	8"	SCH. 80 PVC MAIN SUPPLY TO STATUE FEEDS	1
10	6"	SCH. 80 PVC LOOP SUPPLY TO STATUE FEEDS	2
11	2"	SCH. 80 PVC STATUE NOZZLE FEEDS	8

NOTE: REDUCE ALL PIPE SIZES AS NEAR TO DEVISE OR PENETRATIONS AS POSSIBLE

WATER FEATURE DISCHARGE PIPING LEGEND

SYM	SIZE	DESCRIPTION	#REQ'D
5	1"	SCH. 80 PVC WATERSWITCH SUPPLY AT FIXTURE	48
6	4"	SCH. 80 PVC SUPPLY MANIFOLD PIPING TO WATERSWITCH SUPPLY	2
7	6"	SCH. 80 PVC MAIN SUPPLY TO 4" MANIFOLDS	2
8	3"	SCH. 80 PVC MAIN RETURN TO CENTER NOZZLE ASSEMBLY	1
9	8"	SCH. 80 PVC MAIN SUPPLY TO STATUE FEEDS	1
10	6"	SCH. 80 PVC LOOP SUPPLY TO STATUE FEEDS	2
11	2"	SCH. 80 PVC STATUE NOZZLE FEEDS	8

PLAZA SYSTEM BOULDER FITTING, PIPING AND ELECTRICAL RUNS ARE SHOWN FOR CLARITY ONLY. ACTUAL ROUTING MAY DIFFER IN THE FIELD.

IT SHALL BE THE FOUNTAIN SUB CONTRACTORS RESPONSIBILITY TO COORDINATE PLACEMENT OF ALL PIPING AND CONDUITS TO AVOID CONFLICTS WITH THE DRAINAGE SYSTEM SHOWN ON THE DR SERIES DRAWINGS.

ELECTRICAL CONDUIT

HYDRAULIC PIPING LINES -
 UNDERWATER CABLE -

GENERAL LOCATION OF EQUIPMENT VENTS REFERRED TO IN THIS DRAWING FOR ACTUAL VENT LOCATION.

HOLDING TANK
 6000 GALLONS
 12'X12'X12'

EQUIPMENT VAULT
 25'X25'X14'
 SEE VAULT DETAILS LW.12

