AIR & VACUUM RELEASE VALVE ADJUSTMENT/PROTECTION NOT TO SCALE

REUSE OR REPLACE EXIST C.I. VALVE BOX WITH LID - PROVIDE NEW PAD OVER Q OPERATING NUT 1500# CONC. 18" MIN PROPOSED GROUND EXCESS VALVE STEM EXTENSIO $\langle \phi \rangle$ PROVIDE LONGER STEM-EXTENSTION WITH 2" OPERATING NUT DEMO EXISTING AND COLLAR AS NEEDED CONC. PAD EXISTING GROUND AT STA 221+00 -6" MIN. COVER AT BLOWOFF 2000# CONC. 45° BEND, M.J. OR 90° SR BEND (FLG OR MJ) (USE RESTRAINED JOINT GLANDS ON M. J. 'S) ---EXIST 6" BUTTERFLY VALVE

NOT TO SCALE

BLOWOFF VALVE ADJUSTMENT/PROTECTION

NOTES:

- I. PROTECT A/V RELEASE VALVE ASSEMBLY AT ALL TIMES DURING CONSTRUCTION.
 KEEP CONSTRUCTION TRAFFIC AND MATERIALS AWAY FROM ASSEMBLY AT ALL TIMES.
- 2. MAINTAIN EXISTING GRADE AROUND STEM AND MANHOLE.

NTMWD NOTES:

- I. NORTH TEXAS MUNICIPAL WATER DISTRICT (NTMWD) 30-INCH WATER TRANSMISSION PIPELINE IS LOCATED WITHIN THE LIMITS OF CONSTRUCTION.
- 2. OPERATION OF HEAVY EARTH MOVING EQUIPMENT, COMPACTION EQUIPMENT OR HEAVY CONSTRUCTION EQUIPMENT, SUCH AS CONCRETE TRUCKS, SHALL BE RESTRICTED TO SPECIFIC CROSSING POINTS ACROSS NTMWD EASEMENTS. CONTRACTOR SHALL DESIGNATE A CROSSING LOCATION AND SUBMIT TO NTMWD FOR APPROVAL. LOCATION MUST HAVE A MINIMUM OF 5-FT OF COVER AS FIELD VERIFIED BY THE CONTRACTOR.
- 3. NO MATERIALS SHALL BE STOCKPILED ON THE NTMWD EASEMENT WITHOUT AUTHORIZATION FROM THE NTMWD. IF THE CONTRACTOR DESIRES TO USE NTMWD'S EASEMENT FOR STOCKPILE OF MATERIALS, CONTACT NTMWD ENGINEERING AT 972-442-4505.
- 4. CROSSING OF THE NTMWD EASEMENT WITH OTHER UTILITIES, SUCH AS TV CABLE, PHONE, GAS, AND ELECTRIC, SHALL BE COORDINATED WITH THE NTMWD TO AVOID DAMAGE TO THE NTMWD FACILITIES.
- 5. OUTDOOR LIGHTING, LANDSCAPING, SCREENING WALLS OR OTHER FACILITIES SHALL NOT BE INSTALLED IN NTMWD EASEMENTS WITHOUT WRITTEN APPROVAL OF THE NTWMD.
- 6. UNLESS OTHERWISE SHOWN OR REQUIRED, A MINIMUM OF ONE-FOOT CLEARANCE SHALL BE PROVIDED FOR ALL UTILITIES CROSSING THE NTMWD PIPELINES.
- 7. WATER AND SEWER LINES CROSSING THE NTMWD EASEMENT SHALL BE INSTALLED IN COMPLIANCE WITH THE RULES AND REGULATIONS FOR PUBLIC WATER SYSTEMS PARAGRAPH 290.44(E).
- 8. A MINIMUM OF 3.5 FEET CLEARANCE IS REQUIRED BETWEEN BOTTOM OF SUBGRADE AND TOP OF NTMWD PIPELINE. THE DISTRICT REQUESTS THE LOCATION OF THE WATERLINE BE FIELD VERIFIED AT ALL PROPOSED PAVING AND UTILITY CROSSING DURING THE DESIGN PHASE AND ACCURATELY SHOWN IN PLAN AND PROFILE ON THE EXIST M.J. CAP SO THAT A DISTRICT REPRESENTATIVE CAN BE PRESENT DURING EXCAVATION TO LOCATE AND VERIFY NTMWD FACILITIES.
 - 9. NO STRUCTURES, SUCH AS INLETS, MANHOLES, HEADWALLS, RETAINING WALLS, ETC, ARE PERMITTED WITHIN NTMWD'S EASEMENT.
 - IO. PROPOSED UTILITIES ARE PERMITTED WITHIN EASEMENT ONLY IF CROSSING AT AN ANGLE GREATER THAN 45 DEGREES, OR LESS THAN OR EQUAL TO 90 DEGREES.

BLOWOFF ADJUSTMENT NOTES:

- I. ALL 4-INCH AND 6-INCH PIPE AND FITTINGS SHALL MEET AWWA CIIO FOR DIP CLASS 50 WITH FLANGED JOINTS.
- 2. COAT BOLTS AND NUTS WITH KOPPERS BITUMASTIC NO. 50.
- 3. BLOWOFF SHALL DRAIN AWAY FROM MAIN LINE TO EXISTING DRAINAGE WAY. BLOW OFF ASSEMBLY SHALL BE LOCATED INSIDE PERMANENT EASEMENT FOR NTMWD WATERLINE.
- 4. REPLACE PIPE POLYWRAP WHERE DAMAGED OR MISSING.
- 5. REPLACE BLOWOFF PIPE FROM BEND TO MJ CAP IF NEEDED TO INSURE SEAL AT CAP.
- 6. FIELD VERIFY BLOWOFF PIPE DIAMETER FOR ROCKWALL 20-INCH WATERLINE.

UNDERGROUND UTILITIES

THE LOCATION OF EXISTING UTILITIES SHOWN ON THESE PLANS ARE APPROXIMATE AND BASED ON DATA FURNISHED BY THE CITY OF ROCKWALL. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO LOCATE AND VERIFY ON—SITE THE UTILITIES THAT MAY CONFLICT WITH THE CONSTRUCTION.

RECORD DRAWING

This drawing is a compilation of the original sealed engineering drawing and modifications by addenda, change orders and information furnished by the contractor. Information shown that was provided by the contractor and others not associated with the design engineer cannot be verified for accuracy or completeness. Original sealed drawing is on file at the office of AECOM USA Group, Inc., TBPE REG. NO. F-3082

ORIGINAL DRAWING SEALED & SIGNED BY John W. Lacy, P.E.

TX NO. 90202

NO. REVISION BY DATE



205 BYPASS PHASE 6

UTILITIES LAYOUT

TCB

Approved

Unit PW-DAL-FW

Designed SRR/SDB

B AECOM TCB INC.

WWW.TCB.AECOM.COM

17300 DALLAS PARKWAY, SUITE 1010

DALLAS, TEXAS 75248

Scale: Horz: AS SHOWN
Scale: Vert: AS SHOWN

TCB Project No. 60004153

9 OF 9

114 of 216

p; \4328\60004|53-205bypass\cadd\sheets\phase 6 - fm552 to 205