



NOTES

1. ALL DOWNSPOUTS TO HAVE 2'X2' CONCRETE FLUME WITH A 1" INVERT TO DIRECT WATER TO FLUME. (3000 PSI CONCRETE MIN 5' SACK)
2. ALL FILL TO BE COMPACTED TO 95% STD. DENSITY AND USING A SHEEP'S FOOT ROLLER.
3. ENSURE THAT ALL DRAINAGE FLOWS AWAY FROM BUILDING.
4. THE CONTRACTOR IS TO NOTIFY THE DESIGN ENGINEER IMMEDIATELY IF ANY DISCREPANCY OCCUR ON SITE OR DESIGN.
5. ALL CONSTRUCTION MUST MEET CITY OF ROCKWALL STANDARDS OF DESIGN AND NCTCOG 3RD EDITION STANDARDS.
6. ALL CONCRETE BATCH DESIGNS TO BE APPROVED BY THE CITY OF ROCKWALL ENGINEERING DEPARTMENT.

SCALE 1"=20'

DRAINAGE FLUME	
CITY HALL	
ROCKWALL, TEXAS	
CITY OF ROCKWALL "THE NEW HORIZON"	
DESIGNED: A.W. DRAWN: ACAD CITY HALL.DWG	THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY AMY JO WILLIAMS TEXAS P.E. NO. 99406 ON DATE: MAY 08 SHEET 4

REVISION NO.	REMARKS	DATE