



- UTILITY ADJUSTMENT NOTES:
1. MAINTAIN A MINIMUM OF 3.5 FT CLEARANCE BETWEEN TOP OF WATER PIPES AND SUBGRADE.
 2. ARRANGE FOR RELOCATION OF UTILITY POLE TO NORTH OR SOUTH SIDE OF ROADWAY. DO NOT MOVE POLE INTO NTMWD 20 FT ESMT.
 3. INSTALL STORM PIPING BY TRENCHLESS METHODS TO PROTECT EXISTING WATER PIPES. FIELD VERIFY EXISTING UTILITY LOCATIONS. INSTALL AS SHOWN ON STORM SEWER PLANS.

RECORD DRAWING
 This drawing is a compilation of the original sealed engineering drawing and modifications by addenda, change orders and information furnished by the contractor. Information shown that was provided by the contractor and others not associated with the design engineer cannot be verified for accuracy or completeness. Original sealed drawing is on file at the office of AECOM USA Group, Inc., TBPE REG. NO. F-3082

ORIGINAL DRAWING SEALED & SIGNED BY
 John W. Lacy, P.E.
 TX NO. 90202

NO.	REVISION	BY	DATE

City of Rockwall, Texas

205 BYPASS SECTION 1

UTILITIES LAYOUT 2 OF 6

TCB | AECOM TCB INC. WWW.TCB.AECOM.COM 17300 DALLAS PARKWAY, SUITE 1010 DALLAS, TEXAS 75248

Unit	PW-DAL-FW	Scale:	Horz: AS SHOWN Vert: AS SHOWN	Date	11/11/2009
Designed	SRR/SDB	Checked	TCB	Project No.	60004153
Drawn	FG	Approved	TCB	Sheet	104 of 217

P:\4328\60004153-205Bypass\CADD\Sheets\Sheet\01-140-00-To-FM592\Record Drawing\10_7_09_104EX1.rvt\11/11/2009.dgn
 11/11/2009