



AN EASTECH BADGER MANHOLE FLUME, MODEL-MFB, SHALL BE INSTALLED WITH A VANTAGE 2200 FLOW/LEVEL METER IN THE 8" DIAMETER PIPE. THE METER SHALL HAVE A DATA LOGGER INTEGRAL TO THE ELECTRONICS AND SOFTWARE SHALL BE SUPPLIED FOR DOWNLOADING THE DATA. EACH DEVICE SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.

BENCHMARK #1 (BM1)
 TOP OF FLANGE NUT ON CONCRETE BASE OF LIGHT POLE OF THE FOOTBALL FIELD AND TRACK AT THE NORTHWEST END.
 EL. = 529.40

RECORD DRAWING
 THIS RECORD DRAWING HEREIN REFLECTS TO THE BEST OF THE DESIGN ENGINEER'S KNOWLEDGE, THE APPROXIMATE LOCATION OF THE CONSTRUCTION LIMITS. THE INFORMATION AS PROVIDED BY THE CONTRACTORS.

No.	Date	Revisions	App.
1	9/7/2005	CONSTRUCTION LIMITS NOTED	NES

STATE OF TEXAS
 PROFESSIONAL ENGINEER
 NICHOLAS SILKOWSKI
 8885

ALLIANCE
 ROCKWALL COUNTY
 CITY OF ROCKWALL, TEXAS

SANITARY SEWER
PROFILE

Scale: 1"=40' H., 1"=4' V.
 Designed by: BJG
 Drawn by: DLC
 Checked by: JRH
 Date: SEPTEMBER 2005
 Project No. 064015000

SHEET
 C-17

Kimley-Horn and Associates, Inc.
 12700 Park Central Drive, Suite 1800
 Dallas, Texas 75251
 Tel. No. (972) 770-1300
 Fax No. (972) 239-8820