



STANDARD DRAWINGS OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTING NORTH CENTRAL TEXAS, THIRD EDITION, DATED 1998

> (CITY'S REVISIONS — AUGUST 2003) DRAWINGS TO BE MODIFIED AS FOLLOWS:

STANDARD DRAWING NO. 4050 -

1. EXTENSION STEM TO BE TWO (2) FEET BELOW PAVEMENT SURFACE, INSTEAD OF ONE (1) FOOT.

STANDARD DRAWING NO. 4120 -

1. ALL JOINTS ARE TO BE RESTRAINED. MEGA-LUG OR APPROVED EQUAL.

STANDARD DRAWING NO. 4140 -

1. COPPER SERVICE LINE SHALL BE 1-1/2" OR 2" I.D. C.T.S. POLY TUBE

2. TAPPING SADDLE SHALL BE CLOW F-6350 OR APPROVED EQUAL.

3. CORPORATION STOP SHALL BE 1-1/2" OR 2" MUELLER CORPORATION STOP NO. H-15008 OR HAYS EQUAL.

4. ANGLE STOP (COMPRESSION X 2 BOLT METER FLANGE).

5. METER BOX SHALL BE TWO FEET, SIX-INCHES (2'-6") FROM BACK OF CURB OR AS DIRECTED BY THE CITY.

6. METER BOX SHALL BE EIGHTEEN (18) INCH DIAMETER BY FOURTEEN (14) INCH DEEP CORRUGATED GALVANIZED SLOTTED METER BOX WITH COMPOSITE LID (SEE CITY LID DETAIL).

7. BLUE EMS DISK SHALL BE SET AT MAIN LINE.

8. SEE CITY DETAIL FOR SERVICE METER TAIL CONNECTION.

WALLS 

NOARD WATER 

SHEET