

NOTES:

1. PROVIDE BLACK VINYL COATING ON CHAIN LINK FENCE.
2. SEE CIVIL SHEETS FOR ACCESS ROAD PLAN AND PROFILE.
3. SEE SHEET LS-2 FOR PUMP AND PIPING DETAILS.
4. SEE CIVIL SHEETS FOR INFLUENT PIPE PLAN AND PROFILE.
5. SEE CIVIL SHEETS FOR FORCE MAIN PLAN & PROFILE.

8" SS

SS MANHOLE

27'-0"

25'-0"

34'-0"

ENDURO LO-FLOW ODOR CONTROL CANISTER; OR EQUAL

DEISEL GENERATOR WITH INTEGRAL TANK PER ELECTRICAL DRAWINGS

CONTROL PANEL; PER ELECTRICAL DRAWINGS

DUPLEX LIFT STATION 8" WET WELL

6" DIP

VALVE VAULT

TEMPORARY PUMP CONNECTION

12' WIDE GATE

NOTE 2

12'-0" ACCESS ROAD (PAVEMENT)

8" FLEX BASE WITH TENAX TNT TYPE 450 GEOCOMPOSITE LINER, OR APPROVED EQUAL

SEE CHAIN LINK FENCE DETAIL; NOTE 1

6" PVC FORCE MAIN, NOTE 5

FUTURE LANDSCAPING AS REQUIRED BY CITY OF ROCKWALL STANDARDS (TO BE INSTALLED AFTER WATER IS AVAILABLE FOR IRRIGATION)

AREA FOR EXPANSION OF FUTURE LIFT STATION

28'-0"


37'-0"

SITE PLAN
SCALE: 1"=5'

BAR IS ONE INCH IN LENGTH ON ORIGINAL DRAWING. CHECK SCALE AND ADJUST ACCORDINGLY.
ONE INCH

AS-BUILT APRIL 2014
6/21/13
INFORMATION PROVIDED BY CONTRACTORS
(NOT FIELD VERIFIED)



 PERKINS ENGINEERING CONSULTANTS, INC. TYPE REGISTRATION NO. F-8699 DEVELOPMENT PLANS FOR BREEZY HILL PHASE I ROCKWALL, TEXAS			
LIFT STATION SITE PLAN			
DRAWN BY	DESIGNED BY	CHECKED BY	SHEET NO.
SRG	MAP	MAP	LS-1
JOB NUMBER	DATE	SCALE	
COR 12-001	JUNE 2013	NOTED	