Sta. 6+68.66 Line "A" = Sta. 0+00 Line "B" Const. 4' Dia. Std. M.H.

Sta. 6+68.66 Line "A"

Sta. 6+08.66 Line "A"

Sta. 0+00 Lines "A" & "C" Const. Lift Station / 2 Each 5 H.P. Submersible Pumps with adjustable float controls. Cap. 80 gpm Each Pump at 60' T.D.H.

Const. 6' Dia Pre-Cast Conc. Wet Well & Lift Station

Line "A"

25'

15' Utility Esmt.

Prop. 8" San. Sew.

Line "B"

Prop. 8" Water

10' Utility Esmt.

Install:
1-8"x8"x8" Tee
1-8"x6" Reducer
1-6" Gate Valve
1-Fire Hydrant

Install:
1-8"x8"x1½" Tee
1-1½" Meter, Meter Box, Yoke & 1½" Valve
1-Fire Hydrant Complete
1-8" 90° Bend

Prop. 8" Water

Prop. 8" San. Sew.

15' Utility Esmt.

Prop. 8" San. Sew.

Install:
1-6" San. Sew. Service
1-8"x6" Wye

Install:
1-6" San. Sew. Service
1-8"x6" Wye

Install:
1-6" San. Sew. Service
1-8"x6" Wye

Install:
1-6" San. Sew. Service
1-8"x6" Wye

Install:
1-6" San. Sew. Service
1-8"x6" Wye

Install:
1-8"x8"x2" Tee
1-2" Meter Box (Traffic Type), Yoke, Valve & Meter

Install:
1-8"x8"x2" Tee
1-2" Meter & Meter Box
1-2" Service Line
(Traffic Type Box)

C.O. No. 2

Install:
1-8"x8"x8" Tee
1-8" Gate Valve

Sta. 6+10 Line "B" Const. Std. C.O.

Install:
1-8"x4" Wye
1-4" San. Sewer Service

C.O. No. 2

Install:
1-6" SAN. SEWER SERVICE
1-8"x6" WYE

Install:
1-Fire Hydrant Complete
1-8" 45° Bend

Install:
1-Fire Hydt. Complete

Install:
1-8"x8"x8" Tee
1-8" 45° Bend
2-8" Gate Valve
1-8" Plug

Install:
1-8"x8"x2" Tee
2-2" Meter Box, Yoke, Valve & Meter

Install:
1-8"x8"x8" Tee
1-8" Gate Valve
1-8" Plug
1-8"x8"x1½" Tee
1-1½" Meter Box (Traffic Type), Yoke, Valve & Meter

Install:
1-Fire Hydrant Complete

Install:
1-8"x8"x2" Tee
1-2" Meter Box (Traffic Type), Yoke, Valve & Meter

Install:
1-8"x8"x1½" Tee
1-1½" Meter, Meter Box, Yoke & 1½" Valve
1-Fire Hydrant Complete
1-8" 90° Bend
1-8" Gate Valve

Install:
1-Fire Hydrant Comp.
1-8" 90° Bend
1-8" Gate Valve

10' Utility Esmt.

30' Fire Lane, Access & Utility Esmt.

Prop. 8" Water

Prop. 8" San. Sew.

Prop. 8" Water

Prop. 8" San. Sew.

Prop. 8" Water

Prop. 8" San. Sew