



- GENERAL NOTES:**
REFER TO KEYED NOTES FOR SPECIFIC PLAN INFORMATION
1. NEW WATER LINES SHALL BE CLASS 200 MIN. PVC.
 2. ALL WATER LINES & SEWER LINES SHALL HAVE A MINIMUM OF 10' LATERALLY.
 3. ALL FIRE HYDRANTS SHALL FACE FIRE LANE.
 4. UNDERGROUND FIRE SERVICE SHALL HAVE 10' SEPARATION FROM ADJACENT UTILITIES AND SHALL BE INSTALLED IN ITS OWN TRENCH.
 5.
 - 6 — NEW WATER LINE
 - EXG 8" — EXISTING WATER LINE
 - F — NEW FIRE SERVICE
 - ◆ NEW FIRE HYDRANT
 - ⊗ NEW CUT-OFF VALVE
 6. INSTALLATION OF ALL WATER UTILITIES AND APPURTENANCES SHALL BE PER CITY OF ROCKWALL STANDARDS.
 7. ALL FIRE HYDRANTS SHALL HAVE 5'-0" CLEARANCE IN ALL DIRECTIONS (INCLUDING BOLLARDS).
 8. ALL WATER SERVICES SHALL HAVE APPROVED BACKFLOW PREVENTERS.

- NOTES:**
KEYED NOTES DESIGNATED BY: ○
1. INDICATES AREA OF WATER LINE MODIFICATIONS.
 2. WHERE UNDERGROUND UTILITY WORK REQUIRES REMOVAL OF CONCRETE FIRE LANE CONTRACTOR SHALL REMOVE ENTIRE CONCRETE PANEL AND REPLACE WITH 6" 3600 PSI CONCRETE.

NOT AS-BUILT PLANS.
ENGINEER DIDN'T
PROVIDE RECORD
DRAWINGS TO THE
CITY.



RECORD DRAWINGS
02-28-07
S.P. Daughtery

CE ASSOCIATES
STRUCTURAL, MECHANICAL, ELECTRICAL
2505 HWY. ST., LUBBOCK, TX 79423
TEL: (806) 745-1225
FAX: (806) 745-1225

Architectural Resources
2525 74TH ST., SUITE 200
LUBBOCK, TX 79423
885/FAX (806) 745-1103

**ADDITIONS TO ROCKWALL
CHRYSLER JEEP DODGE
DEALERSHIP**

PROJECT NO. P06-0105
DATE: 2/26/2007
DRW BY: SPD CHK BY: SPD
REVISIONS: 05/16/08

SHEET NO.
23

