



GENERAL NOTES

- ALL STORM WATER PIPES MUST BE RCP UNLESS NOTED OTHERWISE.
- WHERE LATERAL JOINS AT PIPE JOINTS OF DIFFERENT DIAMETERS, THE DOWNSTREAM/BIGGER DIA. PIPE IS TO BE EXTENDED 4.0' UPSTREAM.

REVISED TO CONFORM TO CONSTRUCTION RECORDS.
 DATE: 10/23/06

DOUPHRATE & ASSOCIATES, INC.
 ENGINEERING • PROJECT MANAGEMENT • SURVEYING
 2235 RIDGE RD., # 200 ROCKWALL, TEXAS 75087
 PHONE: (972) 771-9004 FAX: (972) 771-9005

THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY W.L. DOUPHRATE II TEXAS P.E. NO. 00102 ON 10/27/06

STORM SEWER PLAN & PROFILE (LINE A)
 FLAGSTONE ESTATES
 CITY OF ROCKWALL
 ROCKWALL COUNTY, TEXAS

11-15-05	REVISION
KEB	CHECKED
DLB	DRAWN
9/04	DATE
33A	PROJECT
OF	