THE CONTRACTOR IS RESPONSIBLE FOR ENSURING THAT THE SYSTEM(S) BEING INSTALLED COMPLIES WITH ALL LOCALLY ADOPTED CODES, INCLUDING BUT NOT LIMITED TO THE INTERNATIONAL FIRE CODE, NFPA FIRE CODES, AND FIRE DEPARTMENT REQUIREMENTS.

FIRE PROTECTION INFORMATION:
EQUIPMENT CENTER
STRUCTURE SIZE: 240 SF
CONSTRUCTION TYPE: VB
STRUCTURE HEIGHT: 11'-0" FT MAX

16 PROPOSED NON IA SPACES

15' WATER EASEMENT

8" WATER LINE TO COMPLY WITH CITY OF ROCKWALL WATERLINE CONSTRUCTION CODES (NCTUOG 3RD EDITION).

8" WATER VALVE AT UNION.
8" WATER LINE TO BE CLASS 200 C900 PVC.
BLUE EMS DISKS TO BE ON THE WATER LINE AT EVERY CHANGE IN DIRECTION, VALVE, AND SERVICE.

547'-1"

45°

49°

24' FIRE LANE

6" PVC SD

TRUCK SCALE

C.O.

LP

STING FH

PROPOSED FIRE HYDRANT

PROPOSED BOLLARDS (4) WITH REFLECTIVE STRIPES, MIN. OF 5' FROM HYDRANT.

UGT

UGE

SITE (NTS)

AREA OF INTEREST

REVISION	
INITIAL RELEASE	A

STATE OF TEXAS
TODD DWAYNE WINTTERS
87085
LICENSED
PROFESSIONAL ENGINEER
Todd Winttters 12.17.07

RECORD DRAWING
The water line and fire hydrant shown on this plan were constructed in the locations as designed.

IdleAire Technologies Corporation

Copyright © 2007
IdleAire Technologies Corporation
Knoxville, TN

Any reproduction, republication, distribution, display or other commercial use of these materials without prior written consent of IdleAire Technologies Corporation is strictly prohibited.

CAD FILENAME	PRODUCT CODE	REVISION	DWG SIZE	G.O.	DWG	SHEET
TX1861UP01	CIFD	A	D		UP01	1 OF 1

DFTR	DATE
DRG	09-15-07
ENGR	DATE
GFS	06-27-06
ISSUE DATE	SCALE
07-12-07	1" = 20'

EATON | Electrical — LOUISVILLE, TN

TITLE: TA (49) – ROCKWALL, TX – IA SITE TX1861
I-30 AT ROUTE 205, EXIT 68, ROCKWALL, TX 75087

TYPE: UTILITY PLAN — ARRANGEMENT