

AS-BUILT RECORD DRAWING

- ROCKWALL, IN REVIEWING AND RELEASING PLANS FOR CONSTRUCTION, ASSUMES NO RESPONSIBILITY FOR ADEQUACY OR ACCURACY OF DESIGN.
- 2. ALL T.C.E.Q SEPARATION REQUIREMENTS MUST BE 3. THE CONTRACTOR SHALL FIELD VERIFY LOCATIONS AND DEPTHS OF EXISTING UTILITIES PRIOR TO START
- OF CONSTRUCTION. 4. ALL WATER MAINS SHALL HAVE A MINIMUM COVER OF 48 INCHES PER CITY STANDARDS. 5. STORM CONSTRUCTION WILL INCLUDE FURNISHING AND INSTALLING THE MATERIALS AND ALL STORM DRAINS PIPES, BOXES, INLETS, APPURTENANCE,
- INCLUDING EXCAVATION, EMBEDMENT AND BACKFILL, AS SHOWN ON THESE PLANS. 6. CONTRACTOR TO INSTALL BLUE EMS DISKS ON HTE WATER LINE AT EVERY SERVICE CONNECTION, CHANGE INDIRECTION, VALVE, FIRE HYDRANT, AND
- EVERY 250'. 7. CONTRACTOR TO INSTALL DEFLECTIONS PER MANUFACTURERS SPECIFICATIONS IN ORDER TO AVOID CURB INLET. MAINTAIN 2' CLEARANCE FROM BACK OF INLET.

TO THE BEST OF OUR KNOWLEDGE, THE JOHN R. MCADAMS COMPANY, INC. HEREBY STATES THAT THIS PLAN IS AS—BUILT. THIS INFORMATION PROVIDED IS BASED ON SURVEYING AT THE SITE AND INFORMATION PROVIDED BY THE CONTRACTOR.

MCADAMS,
Date:

MCADAMS

MICHAEL D. DUVAL

0

TE

151 2. 10702
Drawn By: ASC
Date: 02/23/2018
Scale: H1"=40'; V 1"=4'
Revisions:
04/23/2018
07/16/2018
09/06/2018
01 /09 /0010

03/11/2019 Signed

17191

C63

OWNER/DEVELOPER RW LADERA, LLC. 361 W. BYRON NELSON BLVD. STE. 104 **ROANOKE, TX 76262** Ph. 817.430.3318 Contact: John Delin