



- GENERAL NOTES**
1. ALL SPOT ELEVATIONS ARE TOP OF PAVING
 2. ALL CURBS ARE 0.5' ABOVE TOP OF PAVING
 3. ALL FILL TO BE COMPACTED WITH SHEEP'S FOOT ROLLER TO 95% STD. DENSITY.
 4. EXTEND OVERFLOW FLUMES ALL THE WAY TO THE BOTTOM OF PONDS.
 5. MIN. 4' WROUGHT IRON FENCE FOR ALL PONDS.
 6. CONTRACTOR TO ENSURE PROPER COORDINATION BETWEEN CIVIL AND ARCHITECTURAL PLANS.
 7. AT SUBGRADE ELEVATION CONTRACTOR SHALL MAKE SURE THAT POSITIVE DRAINAGE EXIST TO MEET THE GRADING INTENT OF THE SITE.
 8. CROSS SLOPE ON SIDE WALK SHALL RANGE BETWEEN 0.5% MIN. AND 2.0% MAX.

LEGEND

EXISTING	PROPOSED

REVISED TO CONFORM TO CONSTRUCTION RECORDS.
 DATE: _____