


4" EXPANSION

JOINT MATERIAL



12" CAP

AS BUILT DRAWINGS

<u>DESIGN BUILDING CODE</u> INTERNATIONAL BUILDING CODE, 2015 EDITION

<u>GEOTECHNICAL\_REPORT</u> FIRM: EWI REPORT NUMBER: LD163803 DATED: MARCH 25, 2016

<u>GEOTECHNICAL CRITERIA</u>

BEARING ON STIFF NATURAL UNDISTURBED CLAYEY SOILS OR COMPACTED AND TESTED SOILS ALLOWABLE BEARING CAPACITY: 2,000 PSF MINIMUM

BACKFILL SOIL PARAMETERS: BACKFILL SOIL – NATURAL CLAYS OR FILL SOILS BACKFILL ANGLE OF INTERNAL FRICTION  $\phi = 28^{\circ}$ 

BASE SOIL PARAMETERS: SOIL AT TOE – NATURAL UNDISTURBED OR FILL SOILS ANGLE OF INTERNAL FRICTION  $\phi = 28^{\circ}$ 

THE BACKFILL SOIL ANGLE OF INTERNAL FRICTION REFERRED TO ABOVE IS COMPOSITE ANGLE OF INTERNAL FRICTION AND INCLUDES BOTH COHESION AND ANGLE OF INTERNAL FRICTION OF THE SOIL.

THE USE OF VERY WET OR VERY DRY BACKFILL SOIL SHOULD BE AVOIDED. THE USE OF HEAVY EQUIPMENT WITHIN 3 FEET OF THE WALL COULD DAMAGE THE STABILITY OF THE WALL AND SHOULD BE AVOIDED.

LOCATE BASE OF WALLS ON UNDISTURBED OR PROPERLY COMPACTED SOIL.

<u>MA TERIALS</u> AVERAGE DENSITY OF MASONRY STONE WALL VARIES FROM 135 PCF TO 145 PCF. SIZE OF STONE WITHIN WALL VARIES FROM 4" TO 18". CONCRETE RUBBLE WITH OR WITHOUT REBAR IS ACCEPTABLE TO BE USED IN THE WALL CONSTRUCTION.

DRAINAGE ZONE MATERIALS MAY BE COMPOSED OF CLEAN GRAVEL OR STONE RANGING FROM 1" TO 5". CONCRETE RUBBLE IS ACCEPTABLE PROVIDED IT IS CLEAN AND GENERALLY FREE OF DUST OR OTHER DELETERIOUS MATERIALS.

PORTLAND CEMENT MORTAR FOR RETAINING WALL CONSTRUCTION: THE PORTLAND CEMENT MORTAR USED FOR CONSTRUCTION OF THE ABOVE GRADE PORTION OF THE MASONRY STONE RETAINING WALLS SHALL BE PROVIDED WITH THE FOLLOWING PROPORTIONS PER CUBIC YARD OF CONCRETE. THE PORTLAND CEMENT MORTAR SUPPLIER SHALL PROVIDE BATCH TICKETS CLEARLY INDICATING THAT THE APPROPRIATE AMOUNT OF MATERIALS ARE PROVIDED IN EACH CONCRETE MIXER TRUCK LOAD. THE BATCH TICKETS SHALL CLEARLY INDICATE THE AMOUNT BATCHED, THE DATE, THE PROJECT NAME, AND SHALL BE PROVIDED TO RPMX CONSTRUCTION FOR REVIEW, DOCUMENTATION, AND FILE.

TYPE F FLY ASH
FINE AGGREGATE
POTABLE WATER
TYPE 1 PORTLAND CEMENT
ADMIXTURE EUCON 100

94 LBS/CY 3,250 LBS/CY 235 LBS/CY 376 LBS/CY 48 OZ/CY AVERAGE


CONCRETE RETARDERS SUCH AS EUCON 100 RETARDER MAY BE USED AT THE DISCRETION OF THE MASONRY WALL CONTRACTOR. A GREATER AMOUNT OF RETARDER (~64 OZ/CY) IS TYPICALLY USED DURING HOT PERIODS. LESS RETARDER (~32 OZ/CY) IS TYPICALLY USED DURING COOLER WEATHER.

THE ABOVE MATERIAL PROPORTIONS WILL PROVIDE A PORTLAND CEMENT MORTAR WITH A COMPRESSIVE STRENGTH OF APPROXIMATELY 2000 PSI. RPM ×CONSTRUCTION DOES NOT REQUIRE ANY CONCRETE TESTING PROVIDED THE ABOVE PROPORTIONS ARE VERIFIED BY BATCH TICKETS.

CONSTRUCTION REVIEWS RPM xCONSTRUCTION SHALL BE CALLED FOR CONSTRUCTION REVIEW OF THE MASONRY WALL.

RETAINING WALL DESIGN CONSTRAINTS RETAINING WALLS SHOULD NOT HAVE SOLID FENCE PLACED ON TOP OF THE WALL OTHER THAN THOSE SHOWN ON THESE PLANS. RETAINING WALLS SHALL NOT HAVE ADDITIONAL SURCHARGE PLACED ABOVE THE WALL OTHER THAN THOSE SHOWN ON THESE PLANS. RETAINING WALLS SHALL NOT HAVE SLOPE AT BASE OF WALL THAT EXCEEDS THOSE SHOWN ON THESE PLANS. ANY RETAINING WALLS UNDER THE ABOVE CONDITIONS WILL REQUIRE SPECIAL DESIGN.

MINOR VARIATIONS IN THE CONSTRUCTION OF THE RETAINING WALLS ON THIS PROJECT MAY BE ACCEPTED AT THE DISCRETION OF THE DESIGN ENGINEER.




NTS

# THE STANDARD

SHEET\_1 OF \_2

ROCKWALL, TX **RETAINING WALL DETAILS** 


PROJECT #




7

MASONRY WALL SCHEDULE - 1500 PSF
COMPACTED AND TESTED OR NATURAL SOILS

			(	COMPACTED	O AND TEST	ED OR NAT	URAL SOILS	)			
WALL HEIGHT	BASE WIDTH	TOE	BASE DEPTH (TOE)	BASE DEPTH (HEEL)	BATTER	MORTAR ZONE	WALL THICKNESS	GRAVEL – BOTTOM	GRAVEL – TOP	GRA VEL PROJECTION	BEARING CAPACITY
Н	В	B1	С	C1	А	E	Т	G1	<i>G2</i>	G3	PSF
1'-0"	1'-3"	0'-0"	0'-6"	0'-0"	0'-2"	FULL MORTAR	1'-2"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
2'-0"	1'-4"	0'-0	0'-9"	0'-0"	0'-4"	FULL MORTAR	1'-2"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
3'-0"	1'-10"	0'-2	0'-11"	0'-0"	0'-6"	FULL MORTAR	1'-4"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
4'-0"	2'-1"	0'-5"	1'-0"	0'-0"	0'-8"	FULL MORTAR	1'-4"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
5'-0"	2'-3"	0'-2"	1'-0"	0'-5"	0'-10"	0'-8"	2'-1"	2'-0"	4'-10"	5'–5"	1500
6'-0"	2'-6"	0'-3"	1'-0"	0'-6"	1'-0"	0'-10"	2'-3"	2'-0"	5'-8"	6'-3"	1500





## MASONRY WALL SCHEDULE - 1500 PSF

			(	COMPACTE	D AND TES	TED OR NAT	URAL SOILS	)			
WALL HEIGHT	BASE WIDTH	TOE	BASE DEPTH (TOE)	BASE DEPTH (HEEL)	BATTER	MORTAR ZONE	WALL THICKNESS	GRAVEL – BOTTOM	GRAVEL – TOP	GRAVEL PROJECTION	BEARING CAPACITY
Н	В	B1	С	C1	A	E	Т	G1	G2	<i>G3</i>	PSF
1'-0"	1'-3"	0'-0"	1'-10"	0'-0"	0'-2"	FULL MORTAR	1'-2"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
2'-0"	1'-4"	0'-0	2'-1"	0'-0"	0'-4"	FULL MORTAR	1'-2"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
3'-0"	1'-10"	0'-2	2'-3"	0'-0"	0'-6"	FULL MORTAR	1'-4"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
4 <i>`</i> -0"	2'-1"	0'-5"	2'-4"	0'-0"	0'-8"	FULL MORTAR	1'-4"	SEE DETAIL A	SEE DETAIL A	SEE DETAIL A	1500
5'-0"	2'-3"	0'-2"	2'-4"	0'-5"	0'-10"	0'-8"	2'-1"	2'-0"	4'-10"	5'-5"	1500
6'-0"	2'-6"	0'-3"	2'-4"	0'-6"	1'-0"	0'-10"	2'-3"	2'-0"	5'-8"	6'-3"	1500

DOUPHRATE & ASSOCIATES 2235 RIDGE ROAD #200 ROCKWALL, TX (972) 771-9004

**RPM xCONSTRUCTION, LLC** 5208 TENNYSON PARKWAY, SUITE 130 PHONE: (214) 239-4722 FAX: (214) 239-4799 **TBPE FIRM #20428** 

### <u>DESIGN BUILDING CODE</u> INTERNATIONAL BUILDING CODE, 2015 EDITION

<u>GEOTECHNICAL\_REPORT</u> FIRM: EWI REPORT NUMBER: LD163803 DATED: MARCH 25, 2016

<u>GEOTECHNICAL CRITERIA</u> BEARING ON STIFF NATURAL UNDISTURBED CLAYEY SOILS OR COMPACTED AND TESTED SOILS ALLOWABLE BEARING CAPACITY: 2,000 PSF MINIMUM

BACKFILL SOIL PARAMETERS: BACKFILL SOIL - NATURAL CLAYS OR FILL SOILS BACKFILL ANGLE OF INTERNAL FRICTION  $\phi = 28^{\circ}$ 

BASE SOIL PARAMETERS: SOIL AT TOE – NATURAL UNDISTURBED OR FILL SOILS ANGLE OF INTERNAL FRICTION  $\phi = 28^{\circ}$ 

THE BACKFILL SOIL ANGLE OF INTERNAL FRICTION REFERRED TO ABOVE IS COMPOSITE ANGLE OF INTERNAL FRICTION AND INCLUDES BOTH COHESION AND ANGLE OF INTERNAL FRICTION OF THE SOIL.

THE USE OF VERY WET OR VERY DRY BACKFILL SOIL SHOULD BE AVOIDED. THE USE OF HEAVY EQUIPMENT WITHIN 3 FEET OF THE WALL COULD DAMAGE THE STABILITY OF THE WALL AND SHOULD BE AVOIDED.

LOCATE BASE OF WALLS ON UNDISTURBED OR PROPERLY COMPACTED SOIL.

AVERAGE DENSITY OF MASONRY STONE WALL VARIES FROM 135 PCF TO 145 PCF. SIZE OF STONE WITHIN WALL VARIES FROM 4" TO 18". CONCRETE RUBBLE WITH OR WITHOUT REBAR IS ACCEPTABLE TO BE USED IN THE WALL CONSTRUCTION.

DRAINAGE ZONE MATERIALS MAY BE COMPOSED OF CLEAN GRAVEL OR STONE RANGING FROM 1" TO 5". CONCRETE RUBBLE IS ACCEPTABLE PROVIDED IT IS CLEAN AND GENERALLY FREE OF DUST OR OTHER DELETERIOUS MATERIALS.

PORTLAND CEMENT MORTAR FOR RETAINING WALL CONSTRUCTION: THE PORTLAND CEMENT MORTAR USED FOR CONSTRUCTION OF THE ABOVE GRADE PORTION OF THE MASONRY STONE RETAINING WALLS SHALL BE PROVIDED WITH THE FOLLOWING PROPORTIONS PER CUBIC YARD OF CONCRETE. THE PORTLAND CEMENT MORTAR SUPPLIER SHALL PROVIDE BATCH TICKETS CLEARLY INDICATING THAT THE APPROPRIATE AMOUNT OF MATERIALS ARE PROVIDED IN EACH CONCRETE MIXER TRUCK LOAD. THE BATCH TICKETS SHALL CLEARLY INDICATE THE AMOUNT BATCHED, THE DATE, THE PROJECT NAME, AND SHALL BE PROVIDED TO RPMX CONSTRUCTION FOR REVIEW, DOCUMENTATION, AND FILE.

> TYPE F FLY ASH FINE AGGREGATE POTABLE WATER TYPE 1 PORTLAND CEMENT ADMIXTURE EUCON 100

94 LBS/CY 3,250 LBS/CY 235 LBS/CY 376 LBS/CY 48 OZ/CY AVERAGE

CONCRETE RETARDERS SUCH AS EUCON 100 RETARDER MAY BE USED AT THE DISCRETION OF THE MASONRY WALL CONTRACTOR. A GREATER AMOUNT OF RETARDER (~64 OZ/CY) IS TYPICALLY USED DURING HOT PERIODS. LESS RETARDER (~32 OZ/CY) IS TYPICALLY USED DURING COOLER WEATHER.

THE ABOVE MATERIAL PROPORTIONS WILL PROVIDE A PORTLAND CEMENT MORTAR WITH A COMPRESSIVE STRENGTH OF APPROXIMATELY 2000 PSI. RPM XCONSTRUCTION DOES NOT REQUIRE ANY CONCRETE TESTING PROVIDED THE ABOVE PROPORTIONS ARE VERIFIED BY BATCH TICKETS.

<u>CONSTRUCTION REVIEWS</u> RPM XCONSTRUCTION SHALL BE CALLED FOR CONSTRUCTION REVIEW OF THE MASONRY WALL.

RETAINING WALL DESIGN CONSTRAINTS RETAINING WALLS SHOULD NOT HAVE SOLID FENCE PLACED ON TOP OF THE WALL OTHER THAN THOSE SHOWN ON THESE PLANS. RETAINING WALLS SHALL NOT HAVE ADDITIONAL SURCHARGE PLACED ABOVE THE WALL OTHER THAN THOSE SHOWN ON THESE PLANS. RETAINING WALLS SHALL NOT HAVE SLOPE AT BASE OF WALL THAT EXCEEDS THOSE SHOWN ON THESE PLANS. ANY RETAINING WALLS UNDER THE ABOVE CONDITIONS WILL REQUIRE SPECIAL DESIGN.

MINOR VARIATIONS IN THE CONSTRUCTION OF THE RETAINING WALLS ON THIS PROJECT MAY BE ACCEPTED AT THE DISCRETION OF THE DESIGN ENGINEER.

<b>EROSION HAZARD WALL SECTION</b>
BLOCK A, LOT 19 - REAR YARD
NTS

## THE STANDARD

ROCKWALL, TX **RETAINING WALL DETAILS** 

2674W