SITE CALLS

1. CONSTRUCT 5" 3,000 PSI REINFORCED CONCRETE PAVEMENT PER GEOTECHNICAL REPORT AND DETAILS.
2. CONSTRUCT 6" INTEGRAL CONCRETE CURB PER CITY STANDARDS.
3. PAINT 4" WHITE PARKING STRIPE PER SPECS.
4. CONSTRUCT DUMPSTER ENCLOSURE PER ARCHITECTURAL DETAIL.
5. PAINT ACCESSIBLE WHITE PARKING SYMBOL PER CITY STANDARDS.
6. PAINT ACCESSIBLE 4" YELLOW PARKING AISLE STRIPES PER CITY.
7. CONSTRUCT CONCRETE ACCESSIBLE RAMP PER CITY STANDARDS.
8. CONSTRUCT CONCRETE STAIRS WITH HANDRAIL. CITY OF ROCKWALL BUILDING DEPARTMENT MUST APPROVE ALL STAIRS. REFER TO ARCHITECTURAL DRAWINGS FOR STAIRS AND HANDRAILS.
9. CONTRACTOR TO DESIGN BUILD DRY STACK RETAINING WALLS PER MANUFACTURERS RECOMMENDED DESIGN STANDARDS AND GUIDELINES.
10. CONSTRUCT CONCRETE SIDEWALK PER DETAIL ON GRADING PLANS C7.0
11. INSTALL ACCESSIBLE PARKING SIGN PER CITY STANDARDS
12. CONSTRUCT CONCRETE PAD FOR DUMPSTER ENCLOSURE. REFER TO ARCHITECTURAL DRAWINGS.
13. CONSTRUCT 4" INTEGRAL CONCRETE CURB PER CITY STANDARDS.
14. PAINT 4" YELLOW "NO PARKING" STRIPES PER CITY STANDARDS.

PAVEMENT NOTES

1. PROVIDE #3 REBAR AT 18" O.C.E.W.
2. PROVIDE SAWCUT CONTRACTION JOINTS AT INTERVALS NOT TO EXCEED 15' O.C.E.W. FOR 5" THICK PAVEMENT AND 18' O.C.E.W. FOR 6" THICK PAVEMENT.
3. SCARIFY AND RECOMPACT SUBGRADE TO 95% STD. PROCTOR DENSITY AND BETWEEN −2% AND +3% OF OPTIMUM MOISTURE.
4. ALL DIMENSIONS ARE FACE TO FACE.
5. NO SAND SHALL BE INSTALLED UNDER PAVING.
6. FIRELANE PAVEMENT SHALL BE 6" 3,600 PSI CONCRETE, 6−SACK MIN. FOR MACHINE POUR AND 6.5−SACK MIN. FOR HAND POUR.

NOT FOR CONSTRUCTION

REVIEW COPY



VICINITY MAP
NOT TO SCALE

24' FIRELANE, ACCESS & UTIL. ESMT. (F.F.)

EX. UTILITY ESMT.

PAINT 6" RED FIRE LANE PER CITY STANDARDS

LANDSCAPING AREA

20.7'R

22.4'R

35' 4 SPACES @ 9'

45' 5 SPACES @ 9' (TYP)

18'

9'

5.2'

EX. UTILITY ESMT.

EX. CURB

10.2'

23.7'

3'

LANDSCAPING AREA

SIAMESE F.D.C.

4.5'

3'R

14.3'R

LANDSCAPING AREA

24' FIRELANE, ACCESS & UTIL. ESMT. (F.F.)

ROCKWALL CROSSING
LOT 1
22.246 AC.

PBA WEST
13,266 S.F.
FF 558.66

NOTE: ALL SIDEWALK AROUND THE BUILDING ARE BY THE BUILDING GENERAL CONTRACTOR.

ROOF SLOPE

80'

UTILITY ESMT.

EX. CURB

154.72'

5.8'

LOT 4
1.208 AC.

168.667'

CONSTRUCT DRY STACK RETAINING WALL PER MANUFATURERS DESIGN STANDARDS AND GUIDELINES

SHIFTING OF WALL FACE CLOSER TO THE BUILDING FOR ANY REASON WILL REQUIRE APPROVAL FROM THE CITY OF ROCKWALL FIRE DEPARTMENT.

10.2'

11.2'

5.3'

9.7'

9'

45'

3 SPACES @ 9'

20'

16.6'

INSTALL CONCRETE BOLLARDS PER ARCH DETAIL

15' X 30' TXU ESMT.

W 252.37'

5' TXU ESMT.

N46°19'47"W 667.33'

TXDOT
VOL. 65, PG. 591
D.R.R.C.T.

PROPERTY LINE

STEP

LANDSCAPING AREA

NOT FOR CONSTRUCTION

REV	DATE	BY	DESCRIPTION

TEXAS ONE CALL SYSTEM 1-800-245-4545 STOP! CALL BEFORE YOU DIG!

0 5 10 20 (IN FEET)

DESIGNED: ____
DRAWN: ____
CHECKED: ____

STATE OF TEXAS MATTHEW D MORGAN 96329 LICENSED PROFESSIONAL ENGINEER

"THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY MATTHEW D. MORGAN 96329 ON THE DATE SHOWN ON THE DAYSTAMP. ALTERATION OF A SEALED DOCUMENT WITHOUT PROPER NOTIFICATION TO THE RESPONSIBLE ENGINEER IS AN OFFENSE UNDER THE TEXAS ENGINEERING PRACTICE ACT"

DATE NAME

ENGINEERS SURVEYORS ARCHITECTS PLANNERS
THE WALLACE GROUP INC.

PBA WEST RETAIL BUILDING
ROCKWALL CROSSING
SITE PLAN

SHEET C4.0 OF 9 SHEETS