



Notes:
 The traffic signal system neutral conductor shall be grounded at the service pole only.
 All bonding and grounding shall be made with the ground rods and the equipment grounding conductor.
 Main disconnect not required.

Notes:
 The traffic signal system neutral conductor shall be grounded at the service pole only.
 All bonding and grounding shall be made with the ground rods and the equipment grounding conductor.
 Main disconnect not required.

CONNECTIONS AT SERVICE SCHEMATIC TY S
 120/240 VOLT - THREE WIRE

CONNECTION AT STEEL POLE BASE

CONNECTIONS AT SIGNAL CONTROLLERS

SIGNAL POLE BASE

SERVICE POLE

SIGNAL CONTROLLER

Elec. Serv. Ty. S (120/240) 000 (NS) GS (T) TP (0)

SERVICE POLE DETAILS

DALLAS DISTRICT STANDARD			
FED. RD. DIV. NO.	PROJECT NO.	SHEET NO.	
6	STP 961830JMM	64	
STATE	CITY	COUNTY	
TEXAS	DALLAS	ROCKWALL	
CONTRACT	SECTION	JOB	HIGHWAY NO.
1014	03	041	FM 740