



StatArea
 Illuminance (Fc)
 Average = 1.34
 Maximum = 13.8
 Minimum = 0.0
 Avg/Min Ratio = 0.00
 Max/Min Ratio = 0.00

01 PHOTOMETRIC SITE PLAN
 SCALE: 1/16" = 1'

Luminaire Schedule										
Symbol	Label	Qty	Description	Lum. Watts	Total Lamp Lumens	Lum. Lumens	LLD	LDD	BF	LLF
☐	A	5	PHILIPS_G18-1-BLC-400PSMH_SYLVANIA_M400/PS/U/BT28	452	31000	10911	0.800	0.900	1.000	0.720
☐	B	8	PHILIPS_101-FT-150PSMH_SYLVANIA_MP150/U/MED	185	12900	4534	0.800	0.900	1.000	0.720

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
GRADE_Planar	Illuminance	Fc	0.71	13.8	0.0	N.A.	N.A.
StatArea	Illuminance	Fc	1.34	13.8	0.0	N.A.	N.A.

ISSUES
REVISIONS

Rockwall Medical Plaza
 FM3097 (HORIZON RD) LOT 3
 ROCKWALL, TX 75032
 Spine Team Texas, PA



PHOTOMETRIC PLAN

THE SEAL APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY SHANNON K. MCCALL, P.E. #82715 ON JUNE 13, 2014. ALTERATION OF A SEALED DOCUMENT WITHOUT PROPER NOTIFICATION TO THE RESPONSIBLE ENGINEER IS AN OFFENSE UNDER THE TEXAS ENGINEERING PRACTICES ACT. THE RECORD COPY OF THIS DRAWING IS ON FILE AT THE OFFICES OF TELIOS, INC. 3535 TRAVIS STREET, DALLAS, TEXAS, 75204.

3535 Travis Street, Ste. 115
 Dallas, Texas 75204
 phone: 214.744.6199
 fax: 214.744.0770
 Texas Registration #F-694

JOB 14146.0100
DATE 06/13/2014
SHEET
E1.01

